

CORRIGENDUM NO.1 & CLARIFICATION NO.1 TO TENDER
NOTIFICATION: CSO/27/POWER TRANSFORMER) DATE: 23.10.2009

(A) The last date for submission/opening of bids for supply of Power Transformers against Tender Notice No. CSO/27/Power Transformer) Date: 23.10.2009 is here by extended up to Date 11.11.2009, same time & same place as already notified earlier.

(B) The following amendments are here by incorporated in the Tender Specification for supply of Power Transformers:

1) Clause No. 7.9, (iv) (Section-IV, Technical Specification):-

In place of “Liquid oil-filled bushing shall be equipped with liquid level indicators and means for sampling and draining the liquid”,

it should be read as

“bushing shall be of only oil communicating type conforming to IS 2099”.

2) Clause No. 8.2.1, (j) (Section-IV, Technical Specification):-

The clause “The above type tests will be conducted by the supplier at their own cost, if the design/test result of the type tested transformer differs from those of the offered transformer as per their bid”

Stands deleted as it is not applicable.

Bidders may take note of above amendments and quote accordingly.

DGM (Tech)