

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

VOLUME- II

(Tender Specification: WESCO/CEO/019)
GROUP-H

[Detail Scope of Supply]
ANNEXURE

Date: 11.09.2007

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

TENDER DOCUMENT FOR
GROUP- H ITEMS

SPECIFICATION FOR GROUP-H ITEMS

CUT-OUT	Rating in Amp.	Quantity in no.
Porcelain rewirable type kit-kat fuse units of reputed brand complete with base & carrier of following ratings with extended terminals as per ISS :	100 A.	780
	200 A.	1030
<u>FUSE WIRE</u>	Rating in Amp.	Quantity in kg.
Annealed tinned copper fuse wire Conforming to IS: 9926/1981 of Capacity, diameter in mm. & SWG, approximate fusing current in Ampere mentioned along the side of this tabulation.	200 A	75
	130 A	150
	102 A	100
	63 A (65 amp)	150
	30 A	100
	15 A	50
	10 A	50
	5 A	50
	3 A	20