

Guaranteed Technical Particulars of G.I Pipe Earthing Device

Sl. No.	Description of Parameters	Expected Value
1	Maker's Name	
2	Standard to which the earthing pipe confirm	REC Standard - J 2
3	Size of the pipe	40 mm Nominal Bore - as per ISS (Medium gauge) 1239/(Part - I)/1979.
4	Length of the pipe	2.5 mtrs.
5	Thickness of the pipe	3.25 mm
6	Outer diameter of the pipe	48.8 mm Maximum. 47.9 mm Minimum.
7	Standard for processing of Galvanisation and testing for uniformity and mass of Zinc coating of the pipe	IS : 2620/1985. IS : 2629/1986. IS : 6745/1972.
8	G.I Clamp for Earthing Pipe	40 mm x 6 mm.
9	G.I Bolts size	5/8" x 1 & 1/2"