

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA  
**WESCO**

---

**VOLUME- II**

**(Tender Specification: WESCO/CEO/020)  
GROUP-B**

**[Detail Scope of Supply]  
ANNEXURE**

**Date: 06.11.2007**

**WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA**  
**WESCO**

---

**TENDER DOCUMENT FOR SUPPLY OF  
GROUP- B ITEMS**

**SPECIFICATION FOR GROUP-B ITEMS**

<b>HT STAY SET</b>	<b>Quantity</b>
H.T Stay sets consisting of stay rod, Anchor plate, single bow down buckle with hot-dipped Galvanisation done as per IS: 2629/1985 (1 st Revision), (Amendment-2) & IS: 4736/1968 (1 st Revision), (Amendment-1) for Hot-dipped Zinc Coating. Drawing provided for reference.	<b>396 sets.</b>

<b>33 KV HT STAY SET</b>	<b>Quantity</b>
33 KV GI STAY SET COMPLETE: H.T Stay sets suitable for 33 kv. System consisting of stay rod, Anchor plate, single bow down buckle as per REC construction standard with hot-dipped Galvanisation done as per IS: 2629/1985 (1 st Revision), (Amendment-2) & IS: 4736/1968 (1 st Revision), (Amendment-1) for Hot-dipped Zinc Coating. Drawing provided for reference.	<b>34 sets.</b>

<b>G.I Pipe Earthing Device</b>	<b>Quantity</b>
G.I Pipe earthing device as per REC Standard – J <sub>2</sub> as per GTP & Dimensional drawing.	<b>230 no.</b>

<b>11 KV Hardware Fittings (T &amp; C) Type</b>	<b>Quantity</b>
11 Kv Hard ware fittings (T & C) type, suitable for AAAC to be used in 11 Kv overhead power line as per REC Construction standard Conforming to IS : 2486 (Part - I)/1993, (2 <sup>nd</sup> Revision), 2486 (Part – II)/1989(2 <sup>nd</sup> Revision), 2486 (Part-III)/1974, ), 2486 (Part – IV)/1981, Reaffirmed – 1991.	<b>1650 no.</b>

VOLUME-II DSS	Specification : WESCO/CEO/020, 07-08
---------------	--------------------------------------