

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

VOLUME- II

(Tender Specification: WESCO/CEO/021)
GROUP-0

[Detail Scope of Supply]
ANNEXURE

Date: 27.09.2008

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

TENDER DOCUMENT FOR
GROUP- O ITEMS

SPECIFICATION FOR GROUP-O ITEMS

11 kv., 200 A HT A.B Switch Female Fixed Contact	Quantity
Female fixed Contact assembly of standard design suitable for 11 Kv, 200 A A.B Switch H.T in complete. Comprising of: Fixed contact, Flat, Jaw, Arcing Horn, Spring	320 no.

11 kv., 400 A HT A.B Switch Female Fixed Contact	Quantity
Female fixed Contact assembly of standard design suitable for 11 Kv, 400 A A.B Switch H.T in complete. Comprising of: Fixed contact, Flat, Jaw, Arcing Horn, Spring	350 no.

11 kv., 200 A HT A.B Switch Male Moving Contact	Quantity
Male Moving Contact assembly of standard design suitable for 11 Kv, 200 A A.B Switch H.T in complete. Comprising of: Angle, Terminal Connector, Rectangular Blade, Arcing Horn, Flexible Copper Braided Strap, Spring	200 no.

11 kv., 400 A HT A.B Switch Male Moving Contact	Quantity
Male Moving Contact assembly of standard design suitable for 11 Kv, 400 A A.B Switch H.T in complete. Comprising of: Angle, Terminal Connector, Rectangular Blade, Arcing Horn, Flexible Copper Braided Strap, Spring	300 no.

Flexible Copper Braided strap 200 Amp.	Quantity
Flexible Copper Braided strap for 11 KV 200 Amp.	300 no.

- N.B:
1. Materials shall be as per GTP's provided.
 2. Type Test report from CPRI or accredited NABL laboratory should be furnished for the make quoted.